




# Heat Pump Technology Update

## Advanced Heat Pumps and Market Changes

Christopher Dymond, Sr Product Manager  
2024 Utility Energy Forum – Cambria CA






# Outline

- Test Procedure and Rating Changes
- New Product – Room Heat Pumps
- Advanced Features and Capabilities
  - Low-Load Efficient
  - Connected Commissioning
- Tax Credit Criteria Changes for 2025



# *Test Procedure and Rating Changes*

# *Heat Pump Ratings are Imperfect Proxies*





# Ratings Don't Correlate Well with Performance

- Lots of examples
- Improving rating representativeness is not easy

Figure 50. Summer 2015 Observed SEER vs. Rated SEER, N=113





Figure 51. Winter 2015 Observed HSPF vs. Rated HSPF, N=57



2016 Cadmus – Minisplit Impact Analysis



# AHRI 210/240 Test Procedure and Rating

*Federal Rule Making is Currently In Progress*

- 2025? – Minor Tweaks
  - Controls Verification Procedure
  - Cold Climate Heat Pump Definition
  - Dual Fuel Metric
- 2029? – Big Changes
  - Name Change: AHRI 1600
  - Updated Load Lines and Bin Hours
  - Rating Metric Change: SEER ⇔ SCORE, HSPF ⇔ SHORE
  - Defrost Penalty if supplemental heat can be used
  - Sensible Heat Ratio Constraint – Fan Limit

A large, faint, light blue geometric logo consisting of three interlocking diamond shapes is centered in the background.

# *New Product – Room Heat Pump*



# Room Heat Pumps Both Heat & Cool

Saddlebag

- Twice as efficient in heating compared to electric resistance
- Limited to mild climates

Window AC  
w/reverse cycle



Images courtesy Midea



Portable  
(dual hose\*)



Image courtesy Gradient





# *Cold Climate Room Heat Pumps*

- Key innovation is use of an atomizer to get rid of condensate and melt water without need of melt water system or risk of freezing water dribbling down the side of the building.
- Two new products are entering the market that can operate below 5F
- These systems are available in limited production runs at a cost of \$3000-\$4000





# Midea PWHP



	Outdoor Condition	Capacity (BTU/hr)	Efficiency
Cooling Mode	95 °F (35 °C)	9010	11.81 EER
Heating Mode	47 °F (8.3 °C)	9050	4.05 COP
	17 °F (-8.3 °C)	9060	2.42 COP
	5 °F (-15 °C)	9000	2.0 COP
Min Temp	-13 °F (-25 °C)	5050	1.41 COP
CEER	16		
SEER2	18.76		
HSPF2	10.12		
Indoor Sound Pressure Level	High	Low	Silent
	51 dB(A)	43 dB(A)	26 dB(A)
Unit Weight	130 lbs		

Specs subject to change



# Gradient All Weather Unit



Image courtesy Gradient

<b>Electrical Requirement</b>	<b>Voltage</b>	<b>Phase</b>	<b>Circuit Amps</b>
	120 VAC	60 Hz	15 A
<b>Thermal Performance</b>	<b>Outdoor Temp</b>	<b>Capacity</b>	<b>Efficiency</b>
	95 °F (35 °C)	9000 BTU/h	10.0 (EER)
	47 °F (8.3 °C)	9000 BTU/h	4.00 (COP)
	17 °F (-8.3 °C)	9000 BTU/h	2.60 (COP)
	5 °F (-15 °C)	7200 BTU/h	2.35 (COP)
	-7 °F (-21.7 °C)	4900 BTU/h	1.71 (COP)
<b>Weight</b>	125 lbs		
<b>Refrigerant</b>	R32		
<b>Indoor Sound Level</b>	<b>High</b>	<b>Medium</b>	<b>Low</b>
	47 dB(A)	44 dB(A)	38 dB(A)

\*Specifications are subject to change.

Specs subject to change



# Room Heat Pump Climate Categories

“Type 3”  
“Type 4”

Category	Heating Range (outdoor Temp)	Active Defrost	Notes
AC with Electric Heater	5 - 75°F	-	Inefficient during heating
AC with Heat Pump	40 - 75°F	NO	Very limited heating range
Mild Climate Heat Pump	17 - 75°F	YES	Not yet available
Cold Climate Heat Pump	5 - 75°F	YES	Available Q4 2024+

**NO** seasonal efficiency rating for window heat pumps. Consequently, they could not qualify for a 30% federal heat pump tax credit





# EPA's New Room HP Test Procedure and Rating



**ENERGY STAR® Program Requirements  
Product Specification for Room Air Conditioners**

**Draft Final Test Method to Determine  
Room Air Conditioner Heating Mode Performance  
April 2024**

**Final version likely  
published in Q3 2024**

Room heat pump: A room air conditioner as defined at 10 CFR 430.2 that utilizes reverse cycle refrigeration as its prime source for heating the indoor space.

- Type 1 heat pump: A room heat pump that does not have active defrost or for which the specified compressor cut-in and cut-out temperatures are not both less than 40°F.
- Type 2 heat pump: A room heat pump that has active defrost and for which the specified compressor cut-in and cut-out temperatures are both less than 40°F but not both less than 17°F.
- Type 3 heat pump: A room heat pump that has active defrost and for which the specified compressor cut-in and cut-out temperatures are both less than 17°F but not both less than 5°F.
- Type 4 heat pump: A room heat pump that has active defrost and for which the specified compressor cut-in and cut-out temperatures are both less 5°F.




# 2023 NEEA Room HP Research

1. Understand the **customer experience** installing, operating and their expectations of what a window heat pump is and does.
2. **Understand, installation, noise,** and any mechanical limitations that may impact performance or customer experience.
3. Understand how **users changed behavior** such that the window HP displaced heating and cooling from preexisting sources.

Aug 1 - Product Council Presentation Recording  
[Northwest Energy Efficiency Alliance \(NEEA\) | Product Council](#)



Images © NEEA





## *Phase 1 Findings*

- Energy and Comfort top priorities  
(Note – efficiency was not top priority once installed)
- Customers already use multiple products to heat and cool their homes – most are familiar with portable products
- 72% completely agree the concept of a dual heat/cool window unit is appealing
- Portability and 120V outlet compatibility drive interest
- Intended use will likely be to improve comfort in rooms or areas not currently well served by existing heating system



## *Phase 2 Observations*

- Most participants were at least somewhat satisfied across all attributes. Participants were most satisfied with the ease of use, followed by overall heating performance, then noise level
- Units worked as expected
- Although installation was considered easy overall, there were some issues
- Once instructed, participants used product for primary heat in space, but w/o guidance they didn't.
- Potential deal breakers: 40°F limit, aesthetics, physical barriers, noise level





## *Next Steps – 2024-2026*

- Lab testing to new test procedure
- Utility Field Pilots and Customer Use tests
- Develop Savings Estimates
- Develop Program Recommendations
- Stack utility incentives with IRA rebate dollars
- Attract new manufacturers and build competitive marketplace to drive price down

A large, faint, light-blue geometric logo is centered in the background. It consists of several overlapping, nested shapes that form a diamond-like pattern with internal lines, resembling a stylized 'S' or a complex architectural element.

# *Advanced Features and Capabilities*



## ***Low Load Efficient (LLE) Heat Pumps***

***When sized right, a variable speed heat pump spends most of its time running at part load.***

***Good VSHPs are **40+% more efficient** when running at minimum output than at full output. (lots of potential benefit)***






# LLE is great in Mild Climates

- Increasing part load efficiency by 12.5% in a mild climate should produce a 7-8% decrease in annual energy use.
- 2020 sales data shows roughly a quarter of sales already achieve this target.
- 250-500 kWh/yr incremental savings for typical existing home

	Annual Savings
Portland	7.9%
Boise	7.4%
Bozeman	4.4%
Sacramento	8.4%
Denver	6.8%
Minneapolis	3.8%
New York City	8.6%
Washington DC	8.2%


*Based on MN CEE modeling work of 2024 for part load efficiency improvement*





# Dual Fuel Systems Need LLE Heat Pumps

- Dual fuel heat pumps cannot operate the heat pump and the gas furnace at the same time\*
- The heat pump never runs at full load, it always runs at part load



Graphic by Slipstream Inc.

A VSHP with a MinCapCOP = 5.0 will use about 20-30% less electricity for heating than a single speed with the same HSPF

\* Because the gas burner is upstream of the heat pump coil



## Dual Fuel with a LLE Heat Pump

- Better savings than a cold climate heat pump\*
- No additional cost
- No change in system design
- Same crossover temperature

Type	Relative Savings
Single Speed	-
Ave VSHP	12%
Low Load Efficient	17%
Cold Climate	15%

These preliminary results based on simple bin-hour model in climate zone 4, with cross over temperature of 32F and similar HSPF2 values. More careful analysis and field or lab testing is needed.


\* crossover point = 32F





# Commissioning is Changing

- HP guides commissioning and generates a report that confirms it setup and operating correctly
- Data collected during commissioning is be stored remotely so that it can be retrieved during service visits and aid diagnosis of system operation
- Systems will last longer and perform better





# Potential Savings

	Fault Name	Estimated Savings <sup>1,2</sup>	Likelihood of Error <sup>3</sup>
Commissioning faults	Reduced Indoor Coil Airflow	5%	33%
	Refrigerant Undercharge/ Overcharge	10%	28%
	Refrigerant Subcooling	8%	Missing Data
	Non-Condensable Gases	2%	Missing Data
Control Settings	Appropriate Aux heat control settings	8%	57%

$$\text{Commissioning Savings} = \sum_{\text{Fault}=i}^n \text{Savings}_i * \text{Likelihood}_i = 9\%$$

(5%\*10% + 10%\*28% + 8%\*57%)

1. 2014 NIST fault impact [study](#)
2. 2023 Ben Larson Research [memo](#)
3. 2019 BPA's CC&S ASHP field [study](#)





# Conservative Estimate of Savings

The fraction of CCX systems that are *actually* commissioned using a certified verification report



$$9\% \times 80\% \times 75\% \sim 5\%$$



Potential savings assuming that all faults are fixed




The fraction of faults that CCX systems correctly identified and resolved during commissioning



# *National Standards and Tax Credit Criteria*



# Federal Minimum Standard





# 2023-2024 Tax Credit Criteria

## CEE AIR SOURCE HEAT PUMPS - South

CEE Split Ducted ASHP Specifications - South				
Level	SEER2	EER2	HSPF2	Connectivity
CEE Tier 1	≥ 15.2	≥ 11.7	≥ 7.8	N/A
CEE Advanced Tier	≥ 17.0	≥ 12.0	≥ 8.0	CEE Demand Response Criteria Level 2

+4%

CEE Non-Ducted ASHP Specification - South				
Level	SEER2	EER2	HSPF2	Connectivity
CEE Tier 1	≥ 15.2	≥ 11.7	≥ 7.8	N/A
CEE Tier 2	≥ 16.0	≥ 12.0	≥ 9.0	N/A
CEE Advanced Tier	≥ 17.0	≥ 13.0	≥ 9.0	CEE Demand Response Criteria Level 2

+20%

CEE Packaged ASHP Specification - South				
Level	SEER2	EER2	HSPF2	Connectivity
CEE Tier 1	≥ 15.2	≥ 10.6	≥ 7.2	N/A
CEE Advanced Tier	≥ 16.0	≥ 11.0	≥ 8.0	CEE Demand Response Criteria Level 2

## CEE AIR SOURCE HEAT PUMPS - North and Canada

CEE Split Ducted ASHP Specifications - North and Canada						
Level	SEER2	EER2	HSPF2	COP at 5°F*	Capacity Ratio^	Connectivity
CEE Tier 1	≥ 15.2	≥ 10.0	≥ 8.1	≥ 1.75	≥ 58% at 17°F/47°F	N/A
CEE Advanced Tier**	≥ 17.0	N/A	≥ 8.1	≥ 1.75	≥ 70% at 5°F/47°F	CEE Demand Response Criteria Level 2

+8%

CEE Non-Ducted ASHP Specification - North and Canada						
Level	SEER2	EER2	HSPF2	COP at 5°F*	Capacity Ratio^	Connectivity
CEE Tier 1	≥ 15.2	≥ 9.0	≥ 8.5	≥ 1.75	≥ 58% at 17°F/47°F	N/A
CEE Tier 2	≥ 16.0	≥ 9.0	≥ 9.5	≥ 1.75	≥ 70% at 5°F/47°F	N/A
CEE Advanced Tier**	≥ 17.0	N/A	≥ 10.0	≥ 1.75	≥ 70% at 5°F/47°F	CEE Demand Response Criteria Level 2

+26%

CEE Packaged ASHP Specification - North and Canada						
Level	SEER2	EER2	HSPF2	COP at 5°F*	Capacity Ratio^	Connectivity
CEE Tier 1	≥ 15.2	≥ 10.0	≥ 8.1	≥ 1.75	≥ 58% at 17°F/47°F	N/A
CEE Advanced Tier**	≥ 16.0	N/A	≥ 9.0	≥ 1.75	≥ 70% at 5°F/47°F	CEE Demand Response Criteria Level 2

^ 5°F, 17°F and 47°F are rated capacity data points as determined per the Appendix MI tests.

\* For the duration of the 2023 calendar year, COP at 5°F ≥ 1.75 may be met using Appendix MI test method OR via DOE sanctioned calculation methodology based on COP at 17°F and COP at 47°F. Starting January 1, 2024, COP at 5°F must be met using the Appendix MI test method.

\*\* For the Advanced Tier, must perform the ENERGY STAR Cold Climate Heat Pump Controls Verification Procedure (CVP) to confirm that the above performance metrics measured at the Appendix MI low ambient test point at 5°F are achieved by the native controls operating as they would in a customer's home.

### ENERGY MANAGEMENT CRITERIA

Scope: Electric and Gas Air Systems

Level	Requirements
CEE Level 1	AHRI Standard 136 as is Either ANS/CTA-2045-A OR OpenADR 2.0 communication interfaces.
CEE Level 2	Both ANS/CTA-2045-A AND OpenADR 2.0 communication interfaces. An open modular physical interface of ANS/CTA-2045-A and a secondary communication interface to facilitate customer interactions.

### DEMAND RESPONSE CRITERIA

Scope: Electric Variable Capacity HVAC Systems, as defined by ANSI Standard 136

Level	Requirements
CEE Level 1	AHRI Standard 136 as is Either ANS/CTA-2045-A OR OpenADR 2.0 communication interfaces.
CEE Level 2	Both ANS/CTA-2045-A AND OpenADR 2.0 communication interfaces. An open modular physical interface of ANS/CTA-2045-A and a secondary communication interface to facilitate customer interactions.



# Tax Credit for Heat Pumps (\$2000)

*IRA defined this as CEE's highest non-advanced tier*

**DRAFT**  
**NOT FINALIZED**  
But likely in 2025+

## 2025+ TAX CREDIT CRITERIA (3 different heat pump types – These are not finalized)

- Split System                    HSPF2  $\geq$  8.0, SEER2  $\geq$  16.0, EER2  $\geq$  9.0
- Packaged System                HSPF2  $\geq$  7.5, SEER2  $\geq$  16.0, EER2  $\geq$  9.0
- Room HP                         HEER  $\geq$  tbd, COP<sub>17</sub>  $\geq$  1.75 Type 3 or Type 4

## ADDITIONAL DESIGNATION (current CEE thinking)

- Advanced Tier                    HSPF2  $\geq$  8.0, SEER2  $\geq$  17.0, EER2  $\geq$  9.0, OpenADR & CTA2045B
- Cold Climate                     HSPF2  $\geq$  8.5, SEER2  $\geq$  17.0, EER2  $\geq$  9.0, COP@5  $\geq$  1.75, CapRatio5  $\geq$  70%
- Adv. Cold Climate                HSPF2  $\geq$  tbd, SEER2  $\geq$  17.0, EER2  $\geq$  9.0, COP@5  $\geq$  tbd, CapRatio5  $\geq$  tbd%

## ADDITIONAL DESIGNATION (Proposed by NEEA to CEE)

- Hot Climate                        Tax Credit + EER2  $\geq$  11.7
- Dual Fuel                         Tax Credit + MinCapCOP47  $\geq$  4.5





*Questions  
and  
Discussion*

